


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:480.11V I:0.1760A P:80.099W PF:0.9479 Freq:59.98Hz Lamp Flux:7893.82x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:80W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

DATA OF LAMP		PHOTOMETRIC DATA Eff: 98.55 lm/W			
NJZ-FEDEL-80-V04-RZ-110-F(480V)		Imax(cd)	3483	S/MH(C0/180)	1.25
NOMINAL POWER(W)	80	LOR(%)	100.0	S/MH(C90/270)	1.27
RATED VOLTAGE(V)	480	TOTAL FLUX(lm)	7893.8	η UP,DN(C0-180)	0.0,47.1
NOMINAL FLUX(lm)	7893.82	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,52.9
LAMPS INSIDE	1	η up(%)	0.0	CIBSE SHR NOM	1.25
TEST VOLTAGE(V)	480	η down(%)	100.0	CIBSE SHR MAX	1.35

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:18 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum,lamp
10	3413	3381	3380	3382	3426	3433	3456	3439	0- 10	328.4	328.4	4.16,4.16
20	3235	3164	3155	3157	3261	3274	3309	3282	10- 20	941.1	1269	16.1,16.1
30	2892	2776	2740	2792	2936	2979	3006	2972	20- 30	1415	2685	34,34
40	2362	2183	2089	2233	2459	2508	2484	2467	30- 40	1643	4328	54.8,54.8
50	1667	1416	1254	1493	1788	1812	1695	1748	40- 50	1527	5855	74.2,74.2
60	982.3	753.1	537.6	808.5	1089	1042	854.2	1002	50- 60	1102	6958	88.1,88.1
70	507.3	315.7	202.6	341.9	580.7	482.5	311.6	466.6	60- 70	620.0	7578	96,96
80	189.3	78.95	61.37	89.67	244.2	144.8	89.81	133.9	70- 80	269.6	7847	99.4,99.4
90	3.261	0	0	0	2.014	0	0	0	80- 90	46.62	7894	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

Conical surface Flux(90deg): 5129.5 lm

%lum = 65.0%

%lamp = 65.0%

Conical surface Flux(120deg): 6957.6 lm

%lum = 88.1%


%lamp = 88.1%

H(β) Range:-90 - 90DEG
 H(β) Interval: 1.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:CL
 Test Date:18 May 2019

V(B) Range:-80 - 80DEG
 V(B) Interval: 5.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
 Humidity:65.0%
 Test Distance:6.010m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES

Test:U:480.11V I:0.1760A P:80.099W PF:0.9479 Freq:59.98Hz Lamp Flux:7893.82x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:80W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A



LUMINANCE cd/(m2)		
G (DEG)	C0/180	C90/270
85	5992	0
80	10902	3534
75	13018	5107
70	14832	5923
65	17003	8766
60	19646	10752
55	22770	15625
50	25940	19503
45	28718	23639


H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:18 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:480.11V I:0.1760A P:80.099W PF:0.9479 Freq:59.98Hz Lamp Flux:7893.82x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:80W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

pcc	80%			70%			50%			30%			10%			0
p _w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
p _{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Coefficients of Utilization(CU)									
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1.0	1.06	1.03	.99	1.04	1.01	.98	.90	.97	.95	.96	.94	.92	.93	.91	.89	.87
2.0	.94	.88	.83	.93	.87	.82	.89	.85	.81	.86	.82	.79	.83	.80	.77	.75
3.0	.84	.77	.71	.83	.76	.70	.80	.74	.69	.77	.72	.68	.75	.70	.67	.65
4.0	.75	.67	.61	.74	.67	.61	.72	.65	.60	.69	.64	.59	.67	.63	.59	.57
5.0	.68	.60	.54	.67	.59	.53	.65	.58	.53	.63	.57	.52	.61	.56	.52	.50
6.0	.62	.53	.47	.61	.53	.47	.59	.52	.47	.57	.51	.46	.56	.50	.46	.44
7.0	.56	.48	.42	.55	.48	.42	.54	.47	.42	.52	.46	.42	.51	.46	.41	.39
8.0	.51	.43	.38	.51	.43	.38	.50	.43	.38	.48	.42	.37	.47	.41	.37	.35
9.0	.47	.40	.34	.47	.39	.34	.46	.39	.34	.45	.38	.34	.44	.38	.34	.32
10.0	.44	.36	.31	.43	.36	.31	.42	.36	.31	.41	.35	.31	.41	.35	.31	.29



H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:18 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:480.11V I:0.1760A P:80.099W PF:0.9479 Freq:59.98Hz Lamp Flux:7893.82x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:80W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients (WEC)										
0.0																	
1.0	.262	.149	.047	.255	.146	.046	.242	.139	.044	.230	.133	.043	.219	.127	.041		
2.0	.253	.139	.043	.247	.136	.042	.236	.131	.041	.225	.126	.040	.216	.122	.038		
3.0	.239	.127	.038	.234	.125	.038	.224	.121	.037	.215	.118	.036	.206	.114	.035		
4.0	.224	.117	.034	.220	.115	.034	.211	.112	.033	.203	.109	.033	.195	.106	.032		
5.0	.210	.107	.031	.206	.106	.031	.198	.103	.030	.191	.101	.030	.184	.098	.030		
6.0	.197	.099	.028	.193	.098	.028	.186	.096	.028	.180	.093	.027	.174	.091	.027		
7.0	.185	.091	.026	.182	.091	.026	.176	.089	.026	.170	.087	.025	.164	.085	.025		
8.0	.174	.085	.024	.171	.084	.024	.166	.083	.024	.160	.081	.023	.155	.080	.023		
9.0	.164	.079	.022	.162	.079	.022	.157	.077	.022	.152	.076	.022	.147	.075	.022		
10.0	.155	.074	.021	.153	.074	.021	.148	.073	.020	.144	.072	.020	.140	.070	.020		

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients (CCEC)									
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.177	.157	.138	.151	.134	.119	.104	.092	.082	.060	.053	.048	.019	.017	.015	
2.0	.167	.132	.103	.143	.114	.089	.098	.079	.062	.057	.046	.036	.018	.015	.012	
3.0	.159	.114	.079	.136	.098	.068	.093	.068	.048	.054	.040	.028	.017	.013	.009	
4.0	.151	.100	.062	.129	.087	.054	.089	.060	.038	.051	.035	.022	.017	.012	.007	
5.0	.143	.090	.050	.123	.078	.044	.085	.054	.031	.049	.032	.018	.016	.010	.006	
6.0	.137	.081	.042	.117	.070	.036	.081	.049	.026	.047	.029	.015	.015	.009	.005	
7.0	.130	.074	.035	.112	.064	.031	.077	.045	.022	.045	.027	.013	.015	.009	.004	
8.0	.124	.068	.030	.107	.059	.026	.074	.042	.019	.043	.025	.011	.014	.008	.004	
9.0	.119	.064	.026	.102	.055	.023	.071	.039	.016	.041	.023	.010	.013	.008	.003	
10.0	.113	.059	.023	.098	.051	.020	.068	.036	.014	.039	.021	.009	.013	.007	.003	

H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:18 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:480.11V I:0.1760A P:80.099W PF:0.9479 Freq:59.98Hz Lamp Flux:7893.82x1 lm										
NAME: LED Explosion-proof Flood Light					TYPE:Floodlight			WEIGHT:N/A		
SPEC.:80W/OSLON Square/5000K					DIM.: N/A			SERIAL No.:N/A		
MFR.: NJZ Lighting Technology Co.,Ltd					SUR.:N/A			Shielding Angle:N/A		
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	16.0	17.3	16.2	17.5	17.7	14.2	15.6	14.5	15.8	16.0
3H	16.9	18.1	17.2	18.4	18.6	14.5	15.8	14.8	16.0	16.2
4H	17.2	18.4	17.5	18.7	18.9	14.6	15.8	14.9	16.0	16.3
6H	17.5	18.6	17.8	18.9	19.1	14.6	15.7	14.9	16.0	16.2
8H	17.5	18.6	17.9	18.9	19.2	14.5	15.6	14.9	15.9	16.2
12H	17.5	18.6	17.9	18.9	19.2	14.5	15.5	14.8	15.8	16.1
4H 2H	16.1	17.3	16.4	17.5	17.8	14.6	15.8	14.9	16.1	16.3
3H	17.1	18.2	17.5	18.5	18.8	15.0	16.0	15.3	16.3	16.6
4H	17.6	18.6	18.0	18.9	19.2	15.1	16.0	15.5	16.4	16.7
6H	18.0	18.8	18.4	19.1	19.5	15.1	16.0	15.5	16.3	16.7
8H	18.1	18.8	18.5	19.2	19.6	15.1	15.9	15.5	16.3	16.6
12H	18.1	18.8	18.5	19.2	19.6	15.1	15.8	15.5	16.2	16.6
8H 4H	17.6	18.3	18.0	18.7	19.1	15.2	16.0	15.6	16.3	16.7
6H	18.0	18.6	18.4	19.0	19.4	15.3	15.9	15.7	16.3	16.7
8H	18.1	18.7	18.6	19.1	19.5	15.3	15.8	15.7	16.2	16.7
12H	18.2	18.6	18.6	19.1	19.6	15.2	15.7	15.7	16.2	16.6
12H 4H	17.5	18.2	17.9	18.6	19.0	15.2	15.9	15.6	16.3	16.7
6H	17.9	18.5	18.4	18.9	19.4	15.3	15.8	15.7	16.2	16.7
8H	18.1	18.6	18.5	19.0	19.5	15.3	15.7	15.7	16.2	16.7
Variations with the observer position at spacings:										
S = 1.0H	+ 0.4 / - 0.5					+ 0.7 / - 0.8				
1.5H	+ 0.2 / - 0.3					+ 0.3 / - 0.5				
2.0H	+ 0.9 / - 0.8					+ 1.4 / - 1.8				

CIE Pub.117, 7894 lm Total Lamp Luminous Flux Correct ($8\log(F/F_0) = 7.2$)

H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:18 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:480.11V I:0.1760A P:80.099W PF:0.9479 Freq:59.98Hz Lamp Flux:7893.82x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:80W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	63	53	46	62	52	46	61	52	46	40
0.80	73	63	56	72	63	56	71	62	56	50
1.00	82	72	66	81	71	65	79	72	65	58
1.25	88	79	73	87	79	73	85	77	72	66
1.50	93	85	79	92	84	78	89	82	77	70
2.00	99	92	86	97	91	86	94	89	84	77
2.50	102	96	91	100	94	90	97	92	88	80
3.00	105	99	95	103	98	94	99	95	92	84
4.00	109	104	100	106	102	99	102	99	96	88
5.00	111	106	103	108	105	101	104	101	98	90
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNM = 1.25		

$H(\beta)$ Range:-90 - 90DEG
 $H(\beta)$ Interval: 1.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:CL
 Test Date:18 May 2019

$V(B)$ Range:-80 - 80DEG
 $V(B)$ Interval: 5.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
 Humidity:65.0%
 Test Distance:6.010m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

Test:U:480.11V I:0.1760A P:80.099W PF:0.9479 Freq:59.98Hz Lamp Flux:7893.82x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:80W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A




H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:18 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

AAI Figure

Test:U:480.11V I:0.1760A P:80.099W PF:0.9479 Freq:59.98Hz Lamp Flux:7893.82x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:80W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Flux out:5431 lm




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:18 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

ISOLUX DIAGRAM

Test:U:480.11V I:0.1760A P:80.099W PF:0.9479 Freq:59.98Hz Lamp Flux:7893.82x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:80W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A



H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:18 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

LED Avg.L Report

Test:U:480.11V I:0.1760A P:80.099W PF:0.9479 Freq:59.98Hz Lamp Flux:7893.82x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:80W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A


AvgL	cd/m2
L_0~180 (65) av	18055
L_0~180 (75) av	14201
L_0~180 (85) av	8899
L_90~270 (65) av	11285
L_90~270 (75) av	6433
L_90~270 (85) av	0
L_45 (65) av	14809
L_45 (75) av	8595
L_45 (85) av	2458

Standard: GB/T 29293-2012

H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:18 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

Planar Illuminance Curve



H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:18 May 2019

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:480.11V I:0.1760A P:80.099W PF:0.9479 Freq:59.98Hz Lamp Flux:7893.82x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:80W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Table--1

UNIT: cd

[illegible]

```
H( $\beta$ ) Range:-90 - 90DEG
H( $\beta$ ) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:18 May 2019
```

```
V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:
```

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:480.11V I:0.1760A P:80.099W PF:0.9479 Freq:59.98Hz Lamp Flux:7893.82x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:80W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Table--2

UNIT: cd

[illegible]

H(β) Range:-90 - 90DEG
H(β) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:18 May 2019

```
V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:
```

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:480.11V I:0.1760A P:80.099W PF:0.9479 Freq:59.98Hz Lamp Flux:7893.82x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:80W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Table--3

UNIT: cd

[illegible]

```
H( $\beta$ ) Range:-90 - 90DEG
H( $\beta$ ) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:18 May 2019
```

```
V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks:
```

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:480.11V I:0.1760A P:80.099W PF:0.9479 Freq:59.98Hz Lamp Flux:7893.82x1 lm		
NAME: LED Explosion-proof Flood Light	TYPE:Floodlight	WEIGHT:N/A
SPEC.:80W/OSLON Square/5000K	DIM.: N/A	SERIAL No.:N/A
MFR.: NJZ Lighting Technology Co.,Ltd	SUR.:N/A	Shielding Angle:N/A

Table--4

UNIT: cd

[illegible]

```
H( $\beta$ ) Range:-90 - 90DEG
H( $\beta$ ) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:CL
Test Date:18 May 2019
```

V(B) Range:-80 - 80DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.366
Humidity:65.0%
Test Distance:6.010m [K=1.0000]
Remarks: